


Installation guide

## **Externally operated valve** Type AV210 - Repair kit



### The repair kit contains:


- 1. Two gaskets (1)
  - (On actuator size 40 (diameter control head) only one gasket included).
- 2. One complete valve plate unit (plug and pin) (2).

**Note:** One gasket is for bronze, and one is for stainless steel.

#### **Tools needed:**

- Vice
- Adjustable wrench
- Hammer
- Mandrel
- Chisel

- 1. Fix the valve.
- 2. Remove sleeve / control top from the valve body.
- 3. Replace the gaskets.



042R9316



# 2 Danfoss 42N265.10 Fix the plug. Remove the pin. 3 Replace the plug and pin. Mark a cross over the hole on the plug Danfoss 42N266.10 Danfoss 42N267.10 with a hammer and a chisel, to prevent the pin to pass though the plug once the new pin is fitted. 1. Fix the plug on piston. 2. Fit the pin through the <u>unmarked</u> pin hole. 1. Mark a cross over the <u>unmarked</u> hole with a hammer and a chisel to fix the pin in plug. 1. Assemble the valve in reverse order.