

**Danfoss A/S**DK-6430 Nordborg
Denmark
CVR nr.: 20 16 57 15Telephone: +45 7488 2222
Fax: +45 7449 0949

EC/EU DECLARATION OF CONFORMITY

Danfoss A/S

Refrigeration & Air Conditioning Controls

declares under our sole responsibility that the products:

Pressure switches**Types:**

1. KP1, KP1A, KP2, KP7BS, KP7ABS, KP7W, KP7B, KP7S, KP17B, KP17W, KP17WB
2. KP6W, KP6B, KP6S, KP6AB, KP6AW, KP6AS
3. KPU6W, KPU6B, KPU16W, KPU16B
4. RT6W, RT6S, RT6B, RT6AB, RT6AW, RT6AS, RT35W, RT36S, RT36B

Covered by this declaration are in conformity with the following directive(s), standard(s) or other normative documents(s), provided that the product is used in accordance with our instructions:

Pressure Equipment Directive 97/23/EC (until 2016.07.18) and **Pressure Equipment Directive 2014/68/EU** (from 2016.07.19)

Equipment cat: IV, Notifying Body: TÜV Rheinland, Notified Body No.: 0035.

Test basis: EN 12263:1998 Refrigerating systems and heat pumps – Safety switching devices for limiting the pressure, Requirements and tests.

1. Conformity assessment module B (production type + module D (TÜV certificates 01 202 931/B-10-0003-02 + 01 202 PL/Q-11-0004)
2. Conformity assessment module B (production type) + module D (TÜV certificates 01 202 931/B-12-0021 + 01 202 PL/Q-11-0004)
3. Conformity assessment module B (production type) + module D (TÜV certificates 01 202 931/B-15-0002 + 01 202 PL/Q-11-0004)
4. Conformity assessment module B (production type) + module D (TÜV certificates 01 202 931/B-11-0010 + 01 202 PL/Q-11-0004)

Low Voltage Directive 2014/35/EU

EN 60947-1:2007 +A2:2014 Specification for low-voltage switchgear and controlgear, General rules

EN 60947-4-1:2010 +A1:2012 Low-voltage switchgear and controlgear, Contactors and motor-starters.

Electromechanical contactors and motor starters

EN 60947-5-1:2004 +A1:2009 Specification for low-voltage switchgear and controlgear, Control circuit devices and switching elements. Electromechanical control circuit devices

RoHS Directive 2011/65/EU

Danfoss hereby confirms that substances regulated by above directive: lead, mercury, cadmium, hexavalent chromium, PBB & PBDE are not deliberately used above limits specified in this directive

Date 2016.04.20	Issued by  Piotr Chylaszek Engineering Manager	Date 2016.04.20	Approved by  Slawomir Kozubowski RD & E Manager
--------------------	--	--------------------	---

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation