

## TYPE APPROVAL CERTIFICATE No. ELE013715XG

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

Description Pressure switches

Type Series KP; KPI; KPS

Applicant DANFOSS A/S

Nordborgvej 81, (Office E14-S1)

DK-6430 Nordborg

**DENMARK** 

Manufacturer DANFOSS POLAND SP. Z.O.O.

Place of manufacture UL. CHRZANOWSKA 5

PL-05-825 GRODZISK MAZOWIECKI

**POLAND** 

Reference standards Rules for the Classification of Ships - Part C - Machinery,

Systems and fire protection - Ch.3, Sect.6, Tab.1.

Issued in HAMBURG on February 12, 2015. This Certificate is valid until February 12, 2020

RINA Services S.p.A.

Giuseppe Russo

This certificate consists of this page and 1 enclosure



## TYPE APPROVAL CERTIFICATE

No. ELE013715XG
Enclosure - Page 1 of 1
Series KP
KPI
KPS

## Description:

The KP and KPI pressure switches and thermostats are used for control, monitoring and alarm systems in wide variety of applications.

Enclosure: IP 30, IP 44 or IP 55 (see data sheet)

The KPS Series consist of a series of pressure and temperature controlled switches. The KPS Series has a high level of enclosure, robust and compact construction and resistance to shock and vibration. Enclosure: IP 67 (including IP X6) according to EN60529.

## Reference Documents:

Data Sheet; IC.PD.P10.F4.02 / 520B6484, Pressure switch and thermostat Types KP and KPI IC.PD.P10.I1.02 / 520B6584, Pressure switch and thermostat Types KPS

HAMBURG February 12, 2015

No. 20 Property of the control of th

RINA Services S.p.A. Via Corsica, 12 - 16128 Genova Tel +39 010 53851 Fax +39 010 5351000